# MODEL AHH-10I -15I -20I

Standard Access Door • 1", 11/2", or 2" Deep • In-Swing • Fabricated • Galvanized Steel

Page 1

## Standard Materials and Construction

FLANGED FRAME: 16 GA. galvanized steel.
DOOR PANELS: 20 GA. galvanized steel.
CHANNEL SUPP.: 16 GA. galvanized steel.

**INSULATION:** 2.25 lb. density polyurethane foam.

HANDLES: Dual-acting die cast zinc.

GASKET: Continuous length replaceable neoprene bulb.

HINGE: Stainless steel continuous type.

**VIEWPORT GLASS:** Single pane, ½" wire; 9" x 9" standard.

FINISH: Mill.

## **Options**

Door panel material: bonderized steel, stainless steel

Viewport glass size: 9" x 9" or 12" x 12"

Single pane 1/4" wire or plexiglass

Double pane 1/4" wire Thermal pane 1/4" wire

Finishes - Baked Enamel, Baked Epoxy, or Prime Coat

Handles - Chrome plated

### Notes

- 1. Hinge always furnished on "B" height dimension.
- 2. (G) designates doors with glass viewports. Specify (L/H) left hand or (R/H) right hand hinge when viewing from the outside.
- 3. 9" x 9" glass viewport not available on units under 18" in width. 12" x 12" viewports are not available on units under 21" in width.
- 4. Unless otherwise specified, door will be fabricated  $\frac{1}{4}$ " under listed size. Dimensional tolerance is  $\pm$  .075.
- 5. Unless otherwise specified, standard viewport locations are as follows:


'H' = 'B' - 11" (±1") when 'B' is 20" to 60"

'H' = 48" (±1") when 'B' is greater than 60"


(When specifying non-standard viewport locations, 'H' cannot be greater than 'B' - 11".)

- 6. Door width cannot exceed two times its height.
- Please refer to the installation instructions for mounting of handles and door assembly mounting.
- 8. In-swing doors are recommended for positive pressures. Out-swing doors are recommended for negative pressures.

# 'A' + 25%" O.D. of Door Frame Flange 'B' + 25%" O.D. of Door Frame Flange



# **Door Sizes**





For handwritten orders, use the schedule block on page 2.

# MODEL AHH-10I -15I -20I

Standard Access Door • 1", 11/2", or 2" Deep • In-Swing • Fabricated • Galvanized Steel

Page 2

# Schedule Block

							,					
74 #	Ot.,	-10I	-15I	-20I	Left Hand	Right Hand	"A" Width	"B" Height	"H" (When Required)			
Item #	Qty				oor nge Openi		ng Size	Non-Standard Viewport Location**			<u>Union Made</u>	
Arch. / Eng.:							EDR:	-	ECN:		Job:	
Contractor:												
Project:							Date:		DWN:		DWG:	

<sup>\*\*</sup> See Note 5 on Page 1.

